



Certificate number: 2307733 (1)

Issued 25/07/2023

Expires 25/01/2024

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Aalberts intergrated piping systems Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Aalberts intergrated piping systems Ltd
St Catherines Avenue
Doncaster
DN4 8DF
united kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2307733

The following products belong to this certificate

PRODUCT DESCRIPTION Range of spherical valves with DZR brass bodies, incorporating chromium plated brass ball and PTFE seats. The valve bodies incorporate 'Tectite' push-fit end connections. For use with copper (manufactured to BS 2871), PEX and polybutylene (manufactured to BS 7291) pipe. ATS3 – Without Production Surveillance.
MODEL(S) TX300, 66001 & 66004, T809, T809T (66012) & T809B (66011)
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 16 Bar@65°C & 10 bar@92°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C Above ground use only.
MARKING Tectite, PC, CR and size on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes