

Product certificate
K45725/04

Issued 2015-05-01
Replaces K45725/03
Page 1 of 3


RYW Press fittings

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Pegler Yorkshire Group Ltd.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K774/06 "Compression fittings to tighten with matching clamping device".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl



Supplier

Pegler Yorkshire Group Ltd
St Catherines Avenue
DONCASTER DN4 8DF
United Kingdom of Great Britain
Telephone +44 (0) 844 243 4400
Telefax +44 (0) 844 243 9870
Internet www.pegleryorkshire.co.uk

**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

RYW Press fittings

PRODUCT SPECIFICATION

The products mentioned below belong to this certificate.

Fittings made out of copper and/or copper tin alloys in the dimensions ϕ 12, 15, 18, 22, 28, 35, 42 and 54 mm.

This concludes an extended program of elbows, tees, reducing pieces, tail pieces, unions, end connections etc. in which in BRL-K774/06 a recommended assortment is indicated.

The fittings are only designed to be used for connections of copper pipes according to BRL-K760 in the qualities "half hard" and "hard".