



*Certificate number: 2506707 (1)*

Issued 10/06/2025

Expires 10/06/2030

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Broen A/S.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

#### Certificate Issued to:

Broen A/S  
Skovvej 30  
DK-5610 Assens  
Denmark



**KUKreg4**

# Product Certificate

Appendix to Certificate number: 2506707

The following products belong to this certificate

<p>PRODUCT DESCRIPTION</p> <p>Range of ball valves with brass bodies and PTFE seals and EPDM 'o' rings.</p> <p>ATS3 – Without Production Surveillance.</p>
<p>MODEL(S)</p> <p>B3800 Female ISO228/1 - G3/8" DN10R</p> <p>B3800 Female ISO228/1 - G1/4" DN10R</p> <p>B3800 Female ISO228/1 - G1/2" DN15R</p> <p>B3800 Female ISO228/1 - G3/4" DN15R</p> <p>B3800 Female ISO228/1 - G1" DN20R</p> <p>B3800 Female ISO228/1 - G1" DN20R</p> <p>B3801 Male ISO228/1 - G3/8" DN10R</p> <p>B3801 Male ISO228/1 - G1/4" DN10R</p> <p>B3801 Male ISO228/1 - G1/2" DN15R</p> <p>B3801 Male ISO228/1 - G3/4" DN15R</p> <p>B3801 Male ISO228/1 - G1" DN20R</p> <p>B3802 Compression Ø10mm DN10R</p> <p>B3802 Compression Ø12mm DN10R</p> <p>B3802 Compression Ø15mm DN15R</p> <p>B3802 Compression Ø12mm DN15R</p> <p>B3802 Compression Ø10mm DN15R</p> <p>B3802 Compression Ø22mm DN15R</p> <p>B3803 Male ISO228/1 - G3/8A DN10R</p> <p>B3803 Male ISO228/1 - G1/2" DN10R</p> <p>B3803 Male ISO228/1 - G1/2A DN15R</p> <p>B3803 Male ISO228/1 - G3/4" DN15R</p> <p>B3804 Compression Ø10mm DN10R</p> <p>B3804 Compression Ø12mm DN10R</p> <p>B3804 Compression Ø15mm DN10R</p> <p>B3805 Male ISO228/1 - G1/2" DN10R</p> <p>B3806 Compression Ø15mm DN10R</p> <p>B3806 Compression Ø10mm DN10R</p> <p>B3806 Compression Ø12mm DN10R</p> <p>B3806 Compression Ø10mm DN10R</p> <p>B3806 Compression Ø8mm DN10R</p> <p>B3806 Compression Ø8mm DN10R</p> <p>B3806 Compression Ø10mm DN10R</p> <p>B3806 Compression Ø8mm DN10R</p> <p>B3806 Compression Ø8mm DN10R</p> <p>B3806 Compression Ø12mm DN10R</p> <p>B3806 Compression Ø10mm DN10R</p> <p>B3806 Compression Ø12mm DN10R</p> <p>B3806 Compression Ø10mm DN15R</p> <p>B3806 Compression Ø15mm DN15R</p> <p>B3856 Compression Ø15mm DN15R</p> <p>B3856 Compression Ø15mm DN15R</p> <p>B3806 Compression Ø18mm DN15R</p> <p>B3806 Compression Ø22mm DN15R</p> <p>B3806 Compression Ø28mm DN20R</p> <p>B3812 Compression Ø12mm DN10R</p> <p>B3812 Compression Ø15mm DN10R</p> <p>B9044 Tectite Ø15/Ø15 DN15R</p>

# Product Certificate

Appendix to Certificate number: 2506707

---

B9045 Compression Ø15mm DN10R B9055 Compression Ø15mm DN10R
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 95°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
MARKING Ballofix, DN, PN DR on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

## Extra Notes