



Recognises that

Aalberts Integrated Piping Systems Ltd
St Catherines Avenue, Doncaster, South Yorkshire, DN4 8DF

Has had the following products certified as complying with:
The Department of Health (DoH) Health Technical Memorandum 04-01: Supplement,
Performance specification D 08: thermostatic mixing valves (healthcare premises) and all applicable requirements.

Description: T-type Thermostatic Mixing Valves

**Models: PEG402 – 15mm & 22mm, PEG402UA – 15mm & 22mm, PEG402UAX – 15mm & 22mm
TX402 – 15mm & 22mm, TX402UA – 15mm & 22mm, TX402UAX – 15mm & 22mm**

For the designations: HP-B, HP-S, HP-W, HP-T44, HP-T46, LP-Be, LP-Se & LP-We

For full details of the certified range of products and any restrictions, please visit the NSF TMV section of the official NSF listings at nsf.org
Products appearing in the NSF official listing for the TMV3 Scheme are authorised to bear the NSF Mark on the left below. NSF does not authorise the use of the UKAS
Product Certification Mark shown on the right below. Please refer to the NSF TMV Certification Policies for mark usage requirements.



Simon Warburton, Operations Manager

Certificate Number: NSF2140 Rev.2
Issue Date: 06-Mar-2025
Expiry Date: 14-Aug-2025



0110

This certificate is the property of NSF and must be returned upon request. This certificate remains valid as long as the above referenced thermostatic mixing valves are listed in the NSF official listing for the referenced standard. For the most current and complete listing information, please access NSF's website (www.nsf.org).