



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6326CT0632

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Aalberts integrated piping systems B.V. Oude Amersfoortseweg 99, NL-1212 AA Hilversum
Distributor <i>Vertreiber</i>	Aalberts integrated piping systems GmbH Am Thyssenhaus 1-3, D-45128 Essen
Product Category <i>Produktart</i>	Valves for drinking water: Hose union anti-vacuum valves - DN 15 to DN 25 inclusive Family H, type B and type D (6326)
Product description <i>Produktbezeichnung</i>	Hose union anti-vacuum valves
Model <i>Modell</i>	8081
Test reports <i>Prüfberichte</i>	Type testing: 57214322-13 from 20.03.2018 (LGW) Laboratory control test: V003/22.3 from 03.06.2022 (LGW) UBA Guideline/BWGL: KA 0355/15 from 14.07.2023 (TZW) Hygienic testing: 408.437/6 from 06.02.2018 (ÖFI) UBA Guideline/BWGL: KA 0152/13 from 18.04.2016 (TZW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-2 (01.01.2008) DIN EN 15096 (01.10.2020) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	20.03.2028 / 24-0544-WNU

7028-01-A-DE

18.06.2024 Bo A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
8081	Type of construction: C Nominal pressure rating: PN 10 Nominal diameter: DN 15	Only in conjunction with sanitary fittings
8081	Type of construction: C Nominal pressure rating: PN 10 Nominal diameter: DN 20	Only in conjunction with sanitary fittings
8081	Type of construction: C Nominal pressure rating: PN 10 Nominal diameter: DN 25	Only in conjunction with sanitary fittings

DW