

Remarks:

- a. FM Approved when supplied with an EPDM Gasket
- b. For installation where greater rigidity of pipe system is required. Not for use as flexible joints in locations subject to earthquake.
- c. Stainless Steel

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	Taiwan

Company

Aalberts integrated piping systems APAC Inc.
No. 295, Sec. 3 Wantan Road, Wantan Pingtung, Taiwan
(R.O. C) 913

<http://shurjoint.com>