

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Couplings, Standard-Rigid

SHURJOINT Model F09

Product Description

[illegible]

[illegible]

Remarks:	a.) Minimum schedule cut groove pipe to be joined: 6 inch or smaller, Schedule 40; 8 inch or larger, Schedule 30 b.) Minimum schedule rolled groove pipe to be joined: 6 inch or smaller, Schedule 10; 8, 10 or 12 inch - 0.188 inch (4.78 mm) wall c.) All couplings in table above, Approved when supplied with an EDPM gasket using standard gasket lubricant d.) Available in either an Orange Painted, Red Painted or Hot Dip Galvanized surface finish
----------	--

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	Taiwan

Company

Aalberts integrated piping systems APAC Inc.
No. 295, Sec. 3 Wantan Road, Wantan Pingtung,
Taiwan (R.O. C) 913
<http://shurjoint.com>