

SHURJOINT Model K-9

Product Description

[illegible]

[illegible]

Yieh Phui Enterprise, State Pipe, "SPS"																							
Youngstown Tube, "Fire-Flo"																							
Schedule 5 Pipe																							
0.188 in. wall Rolled Groove															300 (2070)								
Tai Feng Qiao Metal Products "Flow II"			300 (2070)	300 (2070)			300 (2070)																
"Fire-Thread"			300 (2070)	300 (2070)																			
BS 1387 medium or heavy grade		175 (1205)	175 (1205)	175 (1205)		300 (2070)	175 (1205)		175 (1205)		300 (2070)			300 (2070)									
Allied Tube & Conduit, "XL-II"		175 (1205)	175 (1205)	175 (1205)	175 (1205)		175 (1205)																
Wheatland Tube, "WST"		175 (1205)	175 (1205)	175 (1205)																			
IDOD Systems "Gal-5"		175 (1205)	175 (1205)	175 (1205)																			
Bull Moose "Ultra-EDDY"		175 (1205)	175 (1205)	175 (1205)																			
Allied Tube & Conduit, "Super 40"		300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)																
Allied Tube & Conduit, "Super-XL"		300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)																

Remarks:
a. FM Approved when supplied with an EPDM Gasket
b. For installation where greater rigidity of pipe system is required. Not for use as flexible joints in locations subject to earthquake.

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	Taiwan

Company

Aalberts integrated piping systems APAC Inc.
No. 295, Sec. 3 Wantan Road, Wantan Pingtung, Taiwan (R.O.
C) 913
<http://shurjoint.com>