

SHURJOINT Figure SS-7

Product Description

[illegible]

Schedule 5 Pipe, Rolled Groove																	
0.188 in. wall Rolled Groove																	300 (2070)

Remarks:

a.) Minimum schedule cut groove Stainless Steel pipe to be joined: 6 inch or smaller, Schedule 40; 8 inch or larger, Schedule 30

b.) Minimum schedule rolled groove Stainless Steel pipe to be joined: 6 inch or smaller, Schedule 10; 8, 10, 12 inch - 0.188 inch (5 mm) wall

c.) All couplings in table above, Approved when supplied with an EDPM gasket

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	Taiwan

Company

Aalberts integrated piping systems APAC Inc.
No. 295, Sec. 3 Wantan Road, Wantan Pingtung, Taiwan
(R.O. C) 913
<http://shurjoint.com>