

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Couplings, Standard-Rigid

SHURJOINT Model XH-1000

Product Description

[illegible]

Schedule 5 Pipe, Rolled Groove																				
--------------------------------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Remarks:

a.) Minimum schedule cut groove pipe to be joined: 6 inch or smaller, Schedule 40; 8 inch or larger, Schedule 30

b.) Minimum schedule rolled groove pipe to be joined: 6 inch or smaller, Schedule 10; 8 or 10 inch - 0.188 inch (5 mm) wall; 12 inch – 0.250 in. wall

c.) All couplings in table above, Approved when supplied with an EDPM gasket using standard gasket lubricant

d.) Approved for use with an Orange Painted Finish

e.) Approved for use with a Galvanized Finish according to ASTM A153, Class A specifications

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	Taiwan

Company

Aalberts integrated piping systems APAC Inc.
No. 295, Sec. 3 Wantan Road, Wantan Pingtung,
Taiwan (R.O. C) 913
<http://shurjoint.com>