



Technical approval-with-product certificate K56649/02

Issued 2017-05-01

Replaces K56649/01

page 1 of 3

KAN - therm system

STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

KAN sp. z.o.o.

As specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 E "Plastics piping systems of PE-X/Al intended for the transport of cold and heated drinking water" dated 15-12-2011 inclusive amendment sheet dated 10-03-2015.

Within the framework of this technical approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the plastics piping system, nor the manufacturing of the plastics piping system itself.

Luc Leroy
Kiwa

289170315

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Certificate holder
KAN Sp. z o.o.
Ul. Zdrojowa 51
16-001 BIALYSTOK-KLEOSIN
Poland
T. +48 (0)85 7499 200
F. +48 (0)85 7499 201
kan@kan.com.pl
www.kan.com.pl



Certification process
consists of initial and
regular assessment of:

- quality system
- product

KAN - therm system

PRODUCT SPECIFICATION

Plastics piping systems of PE-X/Al intended for the transport of cold and heated drinking water according to BRL-K536 part E.

The system consists of:

- PE-Xc/Al/PE-Xc pipes manufactured by Becker Plastics GmbH (certificate K44813);
- Metal Fittings manufactured by KAN Sp. z o.o. (certificate K42763);
- PPSU Fittings manufactured by KAN Sp. z o.o. (certificate K42677).

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)	Wall thickness Aluminium (mm)	KAN-therm press
50	4,0	0,5	X
63	4,5	0,5	X

Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products are marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + Class 2/ 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PE-Xc;
- the build up of the pipe; i.e. PE-X/Al;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.





Location of the marks: on every pipe at intervals of not more than 2 m.

The realization of the marks is as follows: clear durable and indelible.

*) for smaller diameters permitted by Kiwa.

Fittings

The minimum required marking on the fittings shall be:


- **KIWA**  or on small products  or  or **KK*** or **KK*** (if not possible **KIWA**  only on the smallest packaging unit)**;
- manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe in mm;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

KAN - therm system

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** ;
- manufacturer's name, trade name, system name, logo or certificate number of the accompanying technical approval (system) certificate, in accordance with the marking of the connecting pipe;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm;
- material identification in case the fitting body is made of plastics.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible.

*) for small fittings marking with only KK is permitted

***) only after approval by Kiwa

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- KAN Sp. z o.o.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.